

City of Amsterdam Fire Department Assembly/Fire Safety Inspection Form

Date of Inspection: 12/30/1899

Battalion:

Street Address: 5555 Any Street

SBL: 55.10-2-32

EXTERIOR

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F304.1	Waste accumulation shall be prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F304.1.2	Vegetation shall be maintained at less than 10".
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F503.1.1	Fire Department apparatus shall be able to access buildings and facilities.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F505.1	Address numbers: contracting, visible, minimum 4" x ½". Address numbers
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F504.1	Exterior doors and openings shall be accessible for fire department operations.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.3	Private fire hydrants (yard hydrants) shall be tested annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.4	Fire Department connections shall be accessible without obstruction.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.5	Fire hydrants shall be accessible without obstruction.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.2	Fire escapes shall be kept clear and unobstructed at all times and shall be maintained in good working order.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.3	Exits and exit discharges shall be free from obstructions or impediments.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F3404.4	Outdoor storage of flammable and combustible liquids shall conform to code & quantity limits.

INTERIOR

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F304.1	Waste accumulation shall be prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F315.2.1	Ceiling clearance: Storage shall be maintained 2 'or more below the ceiling in nonsprinklered areas of buildings.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F315.2.3	Equipment rooms: Combustible material shall not be stored in boiler rooms, mechanical rooms or electrical equipment rooms.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F607.2	Elevator emergency signage is required. The sign shall read: IN FIRE EMERGENCY, DO NOT USE ELEVATOR. USE EXIT STAIRS.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F703.1	Required fire-resistance construction (walls, ceilings, fire stops, shaft enclosures, partitions and floors) shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F703.2	Opening protectives shall be maintained. i.e. fire doors, shutters.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F803.1.1	Furnishings or decorations of an explosive or highly flammable character shall be prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.3	Exits and exit discharges shall be free from obstructions or impediments.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.4	Furnishings, decorations or other objects shall not be placed so as to obstruct exits or visibility thereof.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.6	Emergency escape openings: Required emergency escape openings shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1029.2	Egress doors shall be readily operable from the egress side without the use of a key or special knowledge.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1004.3	Occupant load signage shall be posted near main exit or exit access doorway. Occupant load at ____persons.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1011.1	Exits and exit access doors shall be marked. Exception: Not required in rooms that require one exit.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1011.2	Exit signs shall be illuminated at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1006.1	Means of egress shall be illuminated at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1006.3	Illumination: emergency power for Group A having more than 50 occupants is required. Exception: A-3 having an occupant load < 300.

HAZARDOUS MATERIALS

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F407.3	Individual containers of hazardous materials, cartons or packages shall be marked. Buildings, rooms and spaces containing hazardous materials shall be identified by hazard.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F906.1	Additional fire extinguishers are required near hazardous materials.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F2701.4	Hazardous materials reporting: Hazardous materials shall be reported annually as required by GML Section 209u.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F2701.5.2	Material Safety Data Sheets (MSDS) shall be readily available on the premises
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F3404.3.3	Indoor storage flammable and combustible liquids shall conform to code & quantity limits.

EXTINGUISHERS

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6.1	Portable fire extinguishers shall be tested annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F906.1	Portable fire extinguishers shall be provided. Exception: in A, B & E with sprinkler system. One (1) 2A:10-B:C extinguisher is required for every 3,000 sq. ft. of total floor area and must be within 75' of travel from the farthest area of the floor.

FUEL BURNING EQUIPMENT

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Stove, oven, furnace, boiler, heating device, etc. shall not be defective.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Chimneys, smokestacks, flues, gas vents, smoke pipes and connectors shall be maintained free of rust, cracks and leaks.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F603.4	Unvented portable heaters are prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F603.9	Above-ground gas meters, regulators and piping subject to damage shall be protected by a barrier.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F305.1	Proper clearance from ignition sources shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	FG409.5	Fuel fired equipment shall be supplied with a shutoff valve within 6 feet of appliance.

ELECTRIC

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Electrical wiring shall be firmly secured to the surface on which it is mounted.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	All electrical wiring shall be enclosed or protected.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Overcurrent devices (fuses, breakers) shall be operated in a safe condition and according to design.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.1	Electrical hazards: Check outlets for polarity, ground, GFI function etc.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.3	A working space of not less than 30" width, 36" in depth and 78" in height shall be provided in front of electrical service equipment.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.4	Cube adaptors and unfused plugs strips are prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.6	Open junction boxes and open-wiring splices are prohibited. Covers shall be provided for all boxes.

COOKING

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Exhaust systems for commercial cooking equipment shall be maintained in a safe operating condition.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Hood, grease removal devices, fans, ducts and other devices shall be maintained, clean and free of grease.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F609.2	A Type I hood shall be installed at or above all commercial food heat-processing appliances that produce grease vapors or smoke. (NOTE: THIS REQUIREMENT IS NOT RETROACTIVE)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F609.3	A fire-extinguishing system shall be provided for Type I commercial kitchen hoods. (NOTE: THIS REQUIREMENT IS NOT RETROACTIVE).

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F609.4	Chemical fire suppression systems for Type I kitchen hoods shall be maintained every six months.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Any extinguishing system shall be maintained in a operative condition at all times.

WATER SYSTEMS

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F315.2.1	Storage shall be maintained a minimum of 18" below sprinkler head deflectors in sprinklered areas of buildings.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.3	Private fire hydrants shall be Inspection annually and after each operation; flow test and maintenanced annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.4	Posts, fences, vehicles, etc. shall not be placed or kept near fire hydrants, fire department inlet connections or fire protection system control valves The fire department shall not be deterred or hindered from gaining immediate access to fire protection equipment or fire hydrants.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.5	A 3 foot clear space shall be maintained around the circumference of fire hydrants.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F510.1	Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Fire extinguishing systems shall be maintained in an operative condition at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Control valves to sprinklers shall be secured in the open position. Exception: if the system is monitored.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6.1	Fire protection systems shall be inspected, and tested annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6.2	Records of all system inspections, tests and maintenance shall be maintained for a minimum of 3 years and available to AFD.

FIRE DETECTION

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Fire detection and alarm systems shall be maintained in an operative condition at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.5	Extension cords and flexible cords shall not be a substitute for permanent wiring.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F904.11.5.2	Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.

NOTE: C = Complies N of C = Need of Correction N/A = Not Applicable

Inspector _____ Date _____
 Inspector _____ Date _____

Note / Comments