

## City of Amsterdam Fire Department Multiple Dwelling Unit Inspection Form

Date of Inspection: 12/30/1899

Battalion:

Street Address: 5555 Any Street

SBL: 55.10-2-32

### INTERIOR

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F304.1	Waste accumulation prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F703.1	Required fire-resistance construction (walls, ceilings, fire stops, shaft enclosures, partitions and floors) shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F703.2	Opening protectives shall be maintained. i.e. fire doors, shutters.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.3	Exits and exit discharges shall be free from obstructions or impediments.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1027.4	Furnishings, decorations or other objects shall not be placed so as to obstruct exits or visibility thereof.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.6	Emergency escape openings: required emergency escape openings i.e. doors, windows shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1029.2	Egress doors shall be readily operable from the egress side without the use of a key or special knowledge.

### HAZARDOUS MATERIALS

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F3404.3.3	Indoor storage flammable and combustible liquids shall conform to code & quantity limits.

### FUEL BURNING EQUIPMENT

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Stove, oven, furnace, boiler, heating device, etc. shall not be defective.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Chimneys, smokestacks, flues, gas vents, smoke pipes and connectors shall be maintained free of rust, cracks and leaks.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F603.4	Unvented portable heaters are prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F305.1	Clearance from ignition sources shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	FG409.5	Fuel fired equipment shall be supplied with a shutoff valve within 6 feet of appliance.

### ELECTRIC

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Electrical wiring shall be firmly secured to the surface on which it is mounted.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	All electrical wiring shall be enclosed or protected.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Overcurrent devices (fuses, breakers) shall be operated and maintained in a safe condition and according to design.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.1	Electrical hazards. Check outlets for polarity, ground, GFI function etc.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.4	Cube adaptors and unfused plugs strips are prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.5	Extension cords and flexible cords shall not be a substitute for permanent wiring.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.6	Open junction boxes and open-wiring splices prohibited. Covers shall be provided for all boxes.

### FIRE DETECTION

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Fire detection and alarm systems shall be maintained in an operative condition at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F907.2.10.1.2	Single-or multiple-station smoke alarms shall be installed and maintained at all of the following locations: On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms.

In each room used for sleeping purposes.

**CARBON MONOXIDE DETECTION**

**C**    **N of C**    **NA**  
       

F610.3.2.2

Carbon monoxide detection is required in each unit and on the lowest story containing sleeping units.

NOTE: C = Complies

N of C = Need of Correction

N/A = Not Applicable

Inspector \_\_\_\_\_

Date \_\_\_\_\_

Inspector \_\_\_\_\_

Date \_\_\_\_\_

Note / Comments