

City of Amsterdam Fire Department

Non Residential Inspection Inspection Form

Date of Inspection: 12/30/1899

Battalion:

Street Address: 5555 Any Street

SBL: 55.10-2-32

EXTERIOR

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F304.1	Waste accumulation prohibited
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F304.1.2	Vegetation maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F503.1.1	Fire Department apparatus accessibility.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F505.1	Address numbers: contrasting, visible, minimum 4" x 1/2"
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.3	Private fire hydrants (yard hydrants) tested annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F504.1	Exterior doors and openings are accessible for fire department operations.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.4	Fire Department connections are accessible without obstruction.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.5	Fire hydrants are accessible without obstructions.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.2	Fire Escapes shall be kept clear and unobstructed at all times and shall be maintained in good working order.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.3	Exists and exit discharges shall be free from obstructions or impediments.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F3404.4	Outdoor storage of containers and portable tanks.

INTERIOR

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F304.1	Waste accumulation prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F315.2.1	Ceiling clearance. Storage shall be maintained 2' or more below the ceiling in nonsprinklered areas of buildings.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F315.2.3	Equipment Rooms. Combustible material shall not be stored in boiler rooms, mechanical rooms or electrical equipment rooms.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F607.2	Elevator emergency signage. The sign shall read: IN FIRE EMERGENCY, DO NOT USE ELEVATOR. USE EXIT STAIRS.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F703.1	Maintenance of required fire-resistance construction (walls, fire stops, shaft enclosures, partitions and floors).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F703.2	Opening protectives maintained. i.e. fire doors, shutters.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F803.1.1	Furnishings or decorations of an explosive or highly flammable character prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.3	Exits and exit discharges free from obstructions or impediments.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.4	Furnishings, decorations or other objects shall not be placed so as to obstruct exits or visibility thereof.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1028.6	Emergency escape openings: required emergency escape openings shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1029.2	Egress doors shall be readily operable from the egress side without the use of a key or special knowledge.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1004.3	Occupant load signage posted near main exit or exit access doorway. ("A" occupancy at more than 49 persons). Occupant load at _____ persons.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1011.1	Exits and exit access doors shall be marked. Exception: Not required in rooms that require one exit.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1011.2	Exit signs shall be illuminated at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1006.1	Means of egress shall be illuminated at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F1006.3	Illumination: emergency power for Group A having more than 50 occupants. Exception: A-3 having an occupant load < 300.

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F407.3	Individual containers of hazardous materials, cartons or packages shall be marked. Buildings, rooms and spaces containing hazardous materials shall be identified by hazard.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F906.1	Additional fire extinguishers required near hazardous materials.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F2701.4	Hazardous materials reporting. Hazardous materials shall be reported annually as required by GML Section 209u to be forwarded to AFD by (date:)_____ .
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F2701.5.2	Material Safety Data Sheets (MSDS) shall be readily available on the premises
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F3404.3.3	Indoor storage flammable and combustible liquids.

EXTINGUISHERS

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Portable fire extinguishers shall be tested annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F906.1	Portable fire extinguishers provided. In A,B,E,F,H,I,M,R-1,R-2,& R-4. Exception: in A, B & E with sprinkler system.

FUEL BURNING EQUIPMENT

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Stove, oven, furnace, boiler, heating device, etc. are not defective.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Chimneys, smokestacks, flues, gas vents, smoke pipes and connectors are maintained free of rust, cracks and leaks.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F603.4	Unvented portable heaters prohibited in A,B,E,I,M & R occupancies. Exception: 1 & 2 family dwellings.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	FG409.2	Every gas meter shall be equipped with a shutoff valve located on the supply side of the meter.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F603.9	Above-ground gas meters, regulators and piping subject to damage shall be protected by a barrier
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F305.1	Proper clearance from ignition sources shall be maintained.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	FG409.5	Fuel fired equipment shutoff valve within 6 feet of appliance.

ELECTRIC

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Electrical wiring is firmly secured to the surface on which it is mounted.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	All electrical wiring is enclosed or protected.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Overcurrent (fuses, breakers) devices are operated in a safe condition and according to design.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.1	Electrical hazards. Check outlets for polarity, ground, GFI function, etc.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.3	A working space of not less than 30" width, 36" in depth and 78" in height shall be provided in front of electrical service equipment.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.4	Cube adaptors and unfused plugs strips prohibited.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.5	Extension cords and flexible cords shall not be a substitute for permanent wiring.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F605.6	Open junction boxes and open-wiring splices prohibited. Covers shall be provided for all boxes.

COOKING

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Exhaust systems for commercial cooking equipment shall be maintained in a safe operating condition.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F107.2.1	Hood, grease removal devices, fans, ducts and other devices shall be maintained, clean and free of grease.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F609.2	A Type I hood shall be installed at or above all commercial food heat-processing appliances that produce grease vapors or smoke. (NOTE: THIS REQUIREMENT IS NOT RETROACTIVE)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F609.3	A fire-extinguishing system shall be provided for Type I commercial kitchen hoods. (NOTE: THIS REQUIREMENT IS NOT RETROACTIVE)

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F609.4	Chemical fire suppression for Type I kitchen hoods shall be maintained every six months.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Any extinguishing system shall be maintained in a operative condition at all times.

WATER SYSTEMS

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F315.2.1	Storage shall be maintained a minimum of 18" below sprinkler head deflectors in sprinklered areas of buildings.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.3	Private fire hydrants: Inspection annually and after each operation; flow test and maintenance annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.4	Posts, fences, vehicles, etc. shall not be placed or kept near fire hydrants, fire department inlet connections or fire protection system control valves The fire department shall not be deterred or hindered from gaining immediate access to fire protection equipment or fire hydrants.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F508.5.5	A 3 foot clear space shall be maintained around the circumference of fire hydrants.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F510.1	Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Fire extinguishing systems shall be maintained in an operative condition at all times.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Control valves to sprinklers are secured in the open position. Exception: if the system is monitored.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6.1	Fire protection systems shall be inspected, and tested annually.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6.2	Records of all system inspections, tests and maintenance shall be maintained for a minimum of 3 years and available to AFD.

FIRE DETECTION

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F901.6	Fire detection and alarm systems shall be maintained in an operative condition at all times.

HAZARDOUS MATERIALS

C	N of C	NA		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		Has 209u form been provided?
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	F904.11.5.2	Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.

NOTE: C = Complies N of C = Need of Correction N/A = Not Applicable

Inspector _____ Date _____

Inspector _____ Date _____

Note / Comments